



**Yaskawa J7 Drive Program
for the Carlsen 1hp 230 & 460 volt Screw Sump**

ALL SETTINGS ARE AT DEFAULT EXCEPT FOR THE FOLLOWING

ADDRESS	SET TO	ALTERNATE SETTING	DESCRIPTION
N-01	11 (SET THIS CODE FIRST)	N/A	3 WIRE CONTROL
N-16	2.0	N/A	ACCEL TIME
N-17	1.0	N/A	DECEL TIME
N-37	0	N/A	S3 = 3 WIRE
N-38	5	N/A	S4 = RESET
N-47	1	N/A	PWR LOSS
N-59	4	N/A	COAST ON OT

UPDATED: 1/13/06