



**Yaskawa P7 Drive Program  
for the Waukesha 2065 10 hp 230 volt Pump**

ALL SETTINGS ARE AT DEFAULT EXCEPT FOR THE FOLLOWING

ADDRESS	SET TO	ALTERNATE SETTING	DESCRIPTION
A1-03	3330 (SET THIS CODE FIRST)	N/A	3 WIRE CONTROL
B1-03	1	N/A	COAST TO STOP
C1-01	2	N/A	ACCEL TIME
C1-02	3	N/A	DECEL TIME
E2-01	25.0	N/A	MOTOR FLA
L3-01	0	N/A	STALLP ACCEL SEL
L3-04	0	N/A	STALLP DECEL SEL
L3-06	78	N/A	STALL PREV RUN
L4-05	0	N/A	SIGNAL LOSS
O1-03	1	N/A	DISPLAY UNITS

Updated 4/23/07

**Yaskawa P7 Drive Program  
for the Waukesha 2065 10 hp 460 volt Pump**

ALL SETTINGS ARE AT DEFAULT EXCEPT FOR THE FOLLOWING

ADDRESS	SET TO	ALTERNATE SETTING	DESCRIPTION
A1-03	3330 (SET THIS CODE FIRST)	N/A	3 WIRE CONTROL
B1-03	1	N/A	COAST TO STOP
C1-01	2	N/A	ACCEL TIME
C1-02	3	N/A	DECEL TIME
E2-01	13.3	N/A	MOTOR FLA
L3-01	0	N/A	STALLP ACCEL SEL
L3-04	0	N/A	STALLP DECEL SEL
L3-06	78	N/A	STALL PREV RUN
L4-05	0	N/A	SIGNAL LOSS
O1-03	1	N/A	DISPLAY UNITS

Updated 4/23/07