



**Yaskawa P7 Drive Program
for the Waukesha 30 5 hp 480 volt Pump
with a Pressure Transducer**

ALL SETTINGS ARE AT DEFAULT EXCEPT FOR THE FOLLOWING

ADDRESS	SET TO	ALTERNATE SETTING	DESCRIPTION
A1-03	3330 (SET THIS CODE FIRST)	N/A	3 WIRE CONTROL
B1-04	0	N/A	REVERSE ENABLE
B5-01	1	N/A	PI ENABLE
C1-01	2	N/A	ACCEL TIME
C1-02	1	N/A	DECEL TIME
E2-01	3.0	N/A	MOTOR FLA
H1-04	19	N/A	TERM S6 SEL
H3-09	B	N/A	TERM A2 SET
H3-10	120%	N/A	TERM A2 GAIN
L3-06	43	N/A	STALL PREV RUN
L4-05	0	N/A	SIGNAL LOSS
O1-03	1	N/A	DISPLAY UNITS

**Yaskawa P7 Drive Program
for the Waukesha 30 5 hp 230 volt Pump
with a Pressure Transducer**

ALL SETTINGS ARE AT DEFAULT EXCEPT FOR THE FOLLOWING

ADDRESS	SET TO	ALTERNATE SETTING	DESCRIPTION
A1-03	3330 (SET THIS CODE FIRST)	N/A	3 WIRE CONTROL
B1-04	0	N/A	REVERSE ENABLE
B5-01	1	N/A	PI ENABLE
C1-01	2	N/A	ACCEL TIME
C1-02	1	N/A	DECEL TIME
E2-01	6.0	N/A	MOTOR FLA
H1-04	19	N/A	TERM S6 SEL
H3-09	B	N/A	TERM A2 SET
H3-10	120%	N/A	TERM A2 GAIN
L3-06	48	N/A	STALL PREV RUN
L4-05	0	N/A	SIGNAL LOSS
O1-03	1	N/A	DISPLAY UNITS

Updated 6/13/05

CARLSEN AND ASSOCIATES
1439 GROVE STREET • HEALDSBURG, CA 95404
PHONE (707) 431-2000 • FAX (707) 431-2005