



Program for Positive Displacement Pumps with the G3 Control

THESE SETTINGS ARE FOR THE CONTROLS WITH "NO FRONT COVER" ON THE VFD

ALL SETTINGS ARE AT DEFAULT EXCEPT FOR THE FOLLOWING

ADDRESS	SET TO	ALTERNATE SETTING	DESCRIPTION
SN 03	1111 (SET THIS CODE FIRST)		
BN 01	2.0		ACCEL TIME
BN 02	30/60/130 = 1.0	220/320 = 1.5	DECEL TIM
BN 10	3		
SN 02	OF		
SN 04	0000		
SN 07	0000		
SN 10	1011		
SN 11	0100		
SN 15	00		
CN 05	1.5		
CN 23	7.5		
CN 24	7.5		

Updated: 2/10/05